



NOTE: Wire dimming conductors as Class 1

1 SINGLE FIXTURE




Make sure that the power to the fixture is turned off. Slide the slip ring (A) and the canopy (B) onto the stem (C) and leave some space. Screw the junction box crossbar (D) onto the stem (C).

2 FOR EMERGENCY CIRCUIT




In the case where an **emergency circuit** is required, the wires to the emergency circuit will be passed through a second stem.

3 FOR FIXTURE IN GRID CEILING




In the case where the luminaire is installed on a **grid ceiling**, the power cable will pass outside of the stem.

4




Screw the stems (C) onto the nipple at the ends of the fixture (E).

5 CONTINUOUS SYSTEM




For a continuous system, repeat steps 1 to 3 for all mounting hardware.


6




Remove the top cartridges (F) by pulling up them and disconnect the quick connectors (G). Keep the cartridges (F) in a safe place.




Remove the screws (H) on the joiner and put them in a safe place. Screw the stems (C) onto the end of the fixture. Repeat the stem installation onto the second fixture.



Connect wires between joining fixtures (K) and (J) using wires connectors (I). Push the connectors inside the second fixture (J). **Number of wires may vary.**



Join fixtures using align pins as guide. Put back in place the provided screw (H) (using 3/16" Ball-End Screwdriver (AA) provided). Make sure that no wires are placed in between the extrusions, preventing the fixtures to be joined. Tighten the screw (H) to pull the extrusions together.



Put the top cartridges (F) back by connecting the quick connectors (G).