
# **QUAD N-W FLUORESCENT**

#### PENDANT STEM - INSTALLATION




### IMPORTANT: Installation instructions are shown with Quad Narrow and applies to all Quad sizes

# SINGLE FIXTURE




Remove the lens (A) and place it in a safe place. Install the lamp (B) and put the lens (A) back in place.

# FOR FIXTURE IN GRID CEILING




In the case where the luminaire is installed on a grid ceiling, the power cable will pass outside of the stem.

5




Make sure that the power to the fixture is turned off. Slide the slip ring (C) and the canopy (D) onto the stem (E) and leave some space. Screw the iunction box crossbar (F) with the threaded rods (G) onto the stem (E).



Screw the stems (E) onto the nipple at the ends of the fixture (H).


# NOTE: Wire dimming conductors as Class 1

### FOR EMERGENCY CIRCUIT



In the case where an **emergency circuit** is required, the wires to the emergency circuit will be passed through a second stem.

# **POWER SIDE**




Raise the fixture and tighten the junction box crossbar (F) with screws to the junction box (I). Make wire connection with wire connectors (J). Then slide the canopy (D) and thighten the set up with the slip ring (C).

# **QUAD N-W FLUORESCENT**


#### PENDANT STEM - INSTALLATION








crossbar (F) with screws to the junction box (I). Then slide the canopy (D) and thighten the set up


with the slip ring (C).











thighten the sets up with the slip rings (C).

# **QUAD N-W FLUORESCENT**

### PENDANT STEM - INSTALLATION



